

SANDIA REPORT

SAND2015-8336

Unlimited Release

Printed September 2015

Initial Verification and Validation of RAZORBACK – A Research Reactor Transient Analysis Code

Darren G. Talley

Prepared by
Sandia National Laboratories
Albuquerque, New Mexico 87185 and Livermore, California 94550

Sandia National Laboratories is a multi-program laboratory managed and operated by Sandia Corporation, a wholly owned subsidiary of Lockheed Martin Corporation, for the U.S. Department of Energy's National Nuclear Security Administration under contract DE-AC04-94AL85000.

Approved for public release; further dissemination unlimited.



Sandia National Laboratories

Issued by Sandia National Laboratories, operated for the United States Department of Energy by Sandia Corporation.

NOTICE: This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government, nor any agency thereof, nor any of their employees, nor any of their contractors, subcontractors, or their employees, make any warranty, express or implied, or assume any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represent that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government, any agency thereof, or any of their contractors or subcontractors. The views and opinions expressed herein do not necessarily state or reflect those of the United States Government, any agency thereof, or any of their contractors.

Printed in the United States of America. This report has been reproduced directly from the best available copy.

Available to DOE and DOE contractors from

U.S. Department of Energy
Office of Scientific and Technical Information
P.O. Box 62
Oak Ridge, TN 37831

Telephone: (865) 576-8401
Facsimile: (865) 576-5728
E-Mail: reports@osti.gov
Online ordering: <http://www.osti.gov/scitech>

Available to the public from

U.S. Department of Commerce
National Technical Information Service
5301 Shawnee Rd
Alexandria, VA 22312

Telephone: (800) 553-6847
Facsimile: (703) 605-6900
E-Mail: orders@ntis.gov
Online order: <http://www.ntis.gov/search>



Initial Verification and Validation of RAZORBACK – A Research Reactor Transient Analysis Code

Darren G. Talley
Nuclear Safety Analysis
Sandia National Laboratories
P.O. Box 5800
Albuquerque, New Mexico 87185-1141

Abstract

This report describes the work and results of the initial verification and validation (V&V) of the beta release of the Razorback code. Razorback is a computer code designed to simulate the operation of a research reactor (such as the Annular Core Research Reactor (ACRR)) by a coupled numerical solution of the point reactor kinetics equations, the energy conservation equation for fuel element heat transfer, and the mass, momentum, and energy conservation equations for the water cooling of the fuel elements. This initial V&V effort was intended to confirm that the code work to-date shows good agreement between simulation and actual ACRR operations, indicating that the subsequent V&V effort for the official release of the code will be successful.

ACKNOWLEDGMENTS

The author would like to thank the operations staff of the Annular Core Research Reactor for providing the data and log sheets for the pulse operations, installing the spare instrumented element, and executing the power stepdown operation used in this report. In addition, the author would like to thank Gerald Naranjo for his invaluable help in setting up the data acquisition equipment for the power stepdown operation.

CONTENTS

1. INTRODUCTION	7
1.1. Background	7
1.2. Purpose and Scope	7
1.3. Approach	7
2. GENERAL OVERVIEW OF THE RAZORBACK ACRR MODEL	9
2.1. Reactor Kinetics	9
2.2. Reactivity Control Systems	9
2.3. Fuel Element	11
2.4. Coolant Channel	12
2.5. Reactivity Feedback	12
3. COMPARISON TO ANALYTICAL SOLUTIONS	15
3.1. Reactor Kinetics	15
3.2. Fuel Element Heat Transfer	17
4. COMPARISON TO ACRR PULSE OPERATIONS	21
4.1. Predicted Reactor Peak Power	31
4.2. Predicted Reactor Yield	32
4.3. Predicted Fuel Temperatures	37
4.4. Predicted Reactor Pulse Width Parameters	39
4.5. Predicted Reactor Minimum Period	42
5. COMPARISON TO ACRR TRANSIENT ROD WITHDRAWAL OPERATIONS	45
6. COMPARISON TO A SLOW REACTOR TRANSIENT OPERATION	49
7. COMPARISON TO ACRR STEADY STATE OPERATION	55
8. CONCLUSIONS	57
9. RECOMMENDATIONS FOR FURTHER WORK	59
10. REFERENCES	61
Appendix A: SAMPLE RAZORBACK INPUT FILE	63
Appendix B: PULSE LOG SHEET EXCERPTS	73
DISTRIBUTION	85

FIGURES

Figure 1. Schematic of Fuel Element for Analytical Verification.	17
Figure 2. Razorback Fuel Element Temperature vs. an Analytical Result.	18
Figure 3. Relative Error of Fuel Temperature Prediction and Analytical Solution.	19
Figure 4. Razorback Simulation of a \$1.50 Pulse Operation (#9720).	23
Figure 5. Razorback Simulation of a \$1.50 Pulse Operation (#9720) Showing the Pulse Tail.	24
Figure 6. Razorback Simulation of a \$2.00 Pulse Operation (#9719).	25
Figure 7. Razorback Simulation of a \$2.00 Pulse Operation (#9719) Showing the Pulse Tail.	26
Figure 8. Razorback Simulation of a \$2.50 Pulse Operation (#9718).	27
Figure 9. Razorback Simulation of a \$2.50 Pulse Operation (#9718) Showing the Pulse Tail.	28
Figure 10. Razorback Simulation of a \$3.00 Pulse Operation (#9716).	29
Figure 11. Razorback Simulation of a \$3.00 Pulse Operation (#9716) Showing the Pulse Tail.	30
Figure 12. Comparison of Predicted and ACRR Peak Power for Several Pulses.	31
Figure 13. Depiction of the Integration Ranges of the Reactor Yield Parameters.	32
Figure 14. Comparison of Predicted and ACRR Reactor Yield at Pulse Peak for Several Pulses.	34
Figure 15. Comparison of Predicted and ACRR Reactor Yield at Peak+3FWHM for Several Pulses.	35
Figure 16. Comparison of Predicted and ACRR Total Reactor Yield for Several Pulses.	36
Figure 17. Comparison of Predicted and ACRR Fuel Temperatures for Several Pulses.	38
Figure 18. Depiction of Pulse Width Parameters.	39
Figure 19. Comparison of Predicted and ACRR Pulse Widths for Several Pulses.	41
Figure 20. ACRR Reactor Period Produced From Tabular Power/Time Data in the Diagnostic System Report for Pulse 9720 (\$1.50).	43
Figure 21. Razorback Simulation of TRW Operation 9022.	46
Figure 22. Razorback Simulation of TRW Operation 9023.	47
Figure 23. Comparison of ACRR and Razorback Control Rod Bank Motion During Operation 11278.	50
Figure 24. Comparison of Razorback Predicted Power History to Operation 11278.	51
Figure 25. Comparison of Razorback Predicted Fuel Temperature for Operation 11278.	52
Figure 26. Components of Reactivity Feedback in Razorback Simulation of Operation 11278.	53
Figure 27. Comparison of Steady-State Fuel Temperatures.	55
Figure 28. Difference in Predicted vs. ACRR Fuel Temperature.	56
Figure 29. Relative Difference in Predicted vs. ACRR Fuel Temperature.	56

TABLES

Table 1. Reactor Kinetics Delayed Neutron Precursor Group Parameters Used.	9
Table 2. Transient Rod Bank Differential Worth Input Parameters.	10
Table 3. Fuel Element Model Dimensions.	11
Table 4. Pellet Radial and Element Axial Peaking Distribution Parameters.	12
Table 5. Point Kinetic Benchmark Evaluation for -\$1.0 Step Addition.	15
Table 6. Point Kinetic Benchmark Evaluation for -\$0.5 Step Addition.	15
Table 7. Point Kinetic Benchmark Evaluation for \$0.5 Step Addition.	15
Table 8. Point Kinetic Benchmark Evaluation for \$1.0 Step Addition.	15
Table 9. Point Kinetic Benchmark Evaluation for \$0.1/s Ramp Addition.	16
Table 10. Point Kinetic Benchmark Evaluation for \$2.0 Step Addition with Feedback.	16
Table 11. Reactor Peak Power Comparison for Pulse Operations.	31
Table 12. Reactor Yield Comparison for Pulse Operations.	33
Table 13. PPS Peak Fuel Temperature Comparison for Pulse Operations.	37
Table 14. Pulse Shape Comparisons for Pulse Operations.	40
Table 15. Minimum Period Comparison for Pulse Operations.	42
Table 16. Estimation of Reactivity Addition Using the Minimum Period.	42

NOMENCLATURE

ACRR	Annular Core Research Reactor
BeO-UO ₂	Beryllium Oxide-Uranium Dioxide
DOE	Department of Energy
DSA	Documented Safety Analysis
FWHM	Full Width at Half-Maximum
LEHM	Leading Edge (Width) at Half-Maximum
RHU	Rod Holdup
SNL	Sandia National Laboratories
TEHM	Trailing Edge (Width) at Half-Maximum
TR	Transient Rod
TRW	Transient Rod Withdrawal
V&V	Verification and Validation
ρ	Reactivity
\$	Dollar (a unit of reactivity)

1. INTRODUCTION

1.1. Background

Razorback is a computer code designed to simulate the operation of a research reactor (such as the Annular Core Research Reactor (ACRR)) by a coupled numerical solution of the point reactor kinetics equations, the energy conservation equation for fuel element heat transfer, and the mass, momentum, and energy conservation equations for the water cooling of the fuel elements. Razorback is intended for eventual use for analyses related to the ACRR Documented Safety Analysis (DSA). As such, it is necessary that the code be verified to be solving these equations correctly, and also have its predictive results validated against data collected from actual ACRR operation.

1.2. Purpose and Scope

The purpose of this report is to document the work done to verify and validate the initial beta release of the Razorback code. This work is not intended to be complete or exhaustive, nor is it intended to be the “final” verification and validation (V&V) for the code which will be released for DSA use. Rather, this V&V of the beta release is intended to provide confidence that the code at this stage of development is moving towards producing acceptable results, and to identify areas for improvement and/or corrective development of its use, application, and solution methodology.

The scope of the verification and validation (V&V) includes addressing analytical solutions as well as data collected under normal operating conditions of the ACRR. The RAZORBACK code can be used to simulate ACRR steady-state, pulse, transient rod withdrawal (TRW), and general operational transient operation. Limitations on its current application include conditions after fuel element materials are considered as failed (i.e., melting, or plastic deformation), or once boiling conditions are attained in the coolant channel.

1.3. Approach

The V&V is accomplished in five areas: (1) comparison to analytical solutions, (2) comparison to ACRR pulse operations, (3) comparison to ACRR TRW operations, (4) comparison to ACRR steady-state operation, and (5) comparison to a general ACRR transient operation. The comparison to analytical solutions will verify that the relevant physical models (i.e., equations) have been properly implemented within Razorback, and are providing a correct solution of those equations. The comparison to pulse operations will determine the validity of the coupled reactor kinetics and thermal-hydraulic solutions implemented within Razorback for simulating large rapid reactivity additions at the ACRR. The comparison to TRW and general ACRR transient operations will determine the validity of the coupled reactor kinetics and thermal-hydraulic solutions implemented within Razorback for simulating general ACRR operation. The comparison to ACRR steady-state operation will determine the validity of the thermal-hydraulic solution implemented within Razorback for determining the temperature conditions within an ACRR fuel element for normal operating conditions.

[This page intentionally left blank.]

2. GENERAL OVERVIEW OF THE RAZORBACK ACRR MODEL

This section provides a high level discussion of the input data pertinent to the validation modeling of the ACRR presented in this report. A sample input file is included in Appendix A.

2.1. Reactor Kinetics

The reactor kinetics model consists of the point reactor kinetics equations (see Ref. 1) using six delayed neutron precursor groups. A neutron generation time of 25.5 μ s (Ref. 2) was selected, along with a total delayed neutron fraction of 0.0073 (Ref. 3). The delayed neutron group parameters (group decay constants and production fraction) used are shown in Table 1. These values are from Keepin (Ref. 4), and were used as a carryover of inputs for previous work with PK1D (Ref. 5) analyses of the ACRR. These data are actually for fast fission, where data related to thermal fission would be more suitable for the ACRR. Further, data which also addresses the photoneutron contribution from the BeO would be even more suitable. The selection of more suitable delayed neutron group data should be addressed in the final V&V report.

Table 1. Reactor Kinetics Delayed Neutron Precursor Group Parameters Used.

Delayed Neutron Group	Group Decay Constant λ_i (s ⁻¹)	Group Fraction β_i
1	1.27×10^{-2}	2.77×10^{-4}
2	3.17×10^{-2}	1.5549×10^{-3}
3	1.15×10^{-1}	1.3724×10^{-3}
4	3.10×10^{-1}	2.9711×10^{-3}
5	1.40	9.344×10^{-4}
6	3.87	1.898×10^{-4}

2.2. Reactivity Control Systems

The differential reactivity worth curve for the TR bank is input to Razorback in the form

$$\frac{d\rho}{dz} = A \sin^2[B(z - z_o) + C]$$

Where it is noted that the “A” coefficient is normalized to a total TR bank worth, which is a separate input. The values used for A, B, C, and z_o may be determined from TR bank worth calibration operations or a suitable neutronics codes (e.g., MCNP). For pulse simulations, the coefficients were based on 2011 TR bank worth calibration data (since that was the time of the pulse operations which were to be simulated for this report). The coefficients/constants are shown in Table 2. For simulation of TRW operations, a TR bank differential worth curve was determined using MCNP, and the resulting coefficients/constants are also shown in Table 2.

Table 2. Transient Rod Bank Differential Worth Input Parameters.

Pulse Simulation Inputs		TRW Simulation Inputs	
A	0.0278812	A	0.029823
B	0.0438084	B	0.046813
C	-0.225591	C	-0.002728
z_0	-- ^a	z_0	13.0
TR Bank Worth	\$4.45		\$4.290

a. Not used for pulse simulations.

The basis for using different worth curves is that the TR bank worth calibration is performed by incrementally inserting the TR bank and using the controls rods to re-establish a delayed critical condition. The reactivity worth difference based on the before and after control rod bank positions is considered to be the TR bank reactivity worth difference for that incremental insertion. This bank tradeoff methodology mirrors the manner in which a pulse operation of a given worth is set up. Thus, the relative positions of the control rod and TR banks will be essentially as they are when a pulse operation is set up. As for a TRW operation, the TR bank total worth varies with control rod bank position, and as such the TR bank worth curve will be different with different control rod bank positions. For the TRW operations simulated herein, the control rod bank position was at ~26.5 cm. Thus, a TR bank worth curve determined using MCNP with the control rod bank at 27.50 cm was used for the TRW operation simulations.

To simulate a pulse operation, there are timing issues which must be addressed. First, an actual pulse operation will initiate TR ejection after an initial delay time programmed by the reactor operator in the pulse countdown timer program. This value has typically been set at 165 ms. Thus, the Razorback input herein was set to account for this initial time delay. Additionally, once the 165 ms is attained, there is a delay associated with how quickly the valve which admits high pressure nitrogen to the TR ejection mechanism can open. This delay time is also an input to the Razorback simulation of a pulse. At this point, Razorback determines the acceleration of the TR rod bank based on the input nitrogen pressure, piston area, and TR mass. The pressure was obtained from ACRR operations (65 psig). The piston area (28.96 cm²) was determined from the piston drawing.¹ The TR mass (13.75 kg) was set based on past measurements of TR position vs. time data. The valve opening delay time was set at a value for which the simulated pulse peak time approximately matched the measured pulse peak time (for the pulse to be simulated).

Lastly, the ACRR pulse operation system sets a “rod holdup time” (RHU). The RHU time value (0.4 seconds for the pulses being simulated) is the time (from t=0) at which a gravity drop of the transient rods, safety rods, and control rods will be initiated. At this point in the pulse simulation, Razorback will initiate all rods dropping after a simulated electric circuit delay (set using the “Scram Delay Time” input), and the downward acceleration of the rods will be determined assuming that the rods would fall by 55.00 cm over the input “Rod Fall Time.” The inputs selected (50 ms scram delay time, and 500 ms rod fall time) were set to attain the impact of the rod drops on the simulated pulse tails.

¹ Automated Concepts Inc. Drawing 2062M205, Rev. A.

2.3. Fuel Element

The fuel element model for the ACRR was defined using the dimensions from ACRR drawings. The model explicitly includes the BeO-UO₂ fuel pellets (inner and outer), the niobium fuel cups, the stainless steel cladding, and the gaps (helium filled) between the fuel pellets, niobium, and cladding. The model dimensions are shown in Table 3. The energy deposition factors were determined using MCNP. Razorback input was set such that radial thermal expansion of the fuel element materials was computed, and radiation heat transfer across the helium filled gaps was computed.

Table 3. Fuel Element Model Dimensions.

Material	Inner Radius (cm)	Outer Radius (cm)	Number of Nodes	Energy Deposition Fraction
BeO-UO ₂	0.24130	1.09982	10	0.97846 ^a
He	1.09982	1.11760	10	0.0
BeO-UO ₂	1.11760	1.68402	10	0.97846 ^a
He	1.68402	1.73228	10	0.0
Nb	1.73228	1.77038	10	0.00400
He	1.77038	1.82245	10	0.00
SS-304	1.82245	1.87325	10	0.00456

a. As currently configured in Razorback, the energy deposition factor (EDF) applies to the material, and not to the zone. Thus, 97.846% of the energy deposition is in the BeO-UO₂ material. This is simply an artifact of using a single fuel pellet (vs. two pellets separated by a small gap) in the MCNP model used to compute the EDFs. This approach may be revised in future versions for increased generality.

The radial fission density peaking distribution across the BeO-UO₂ fuel pellet in Razorback is of the form

$$f(r) = Ae^{B \cdot r} + C$$

Values used for A, B, and C are given in Table 4 (Ref. 6).

The axial fission density peaking distribution over the length of the fuel element in Razorback is of the form

$$f(z) = \sum_{i=0}^6 a_i \left(\frac{z}{H}\right)^i$$

where H is the height of the fuel stack. Values used for the polynomial coefficients are shown in Table 4 (Ref. 6).

Table 4. Pellet Radial and Element Axial Peaking Distribution Parameters.

Fuel Pellet Radial Distribution Coefficients		Fuel Axial Distribution Coefficients	
A	0.0157	a ₀	0.7721
B	1.9370 cm ⁻¹	a ₁	-0.6252
C	0.8211	a ₂	24.0903
		a ₃	-89.6026
		a ₄	141.5383
		a ₅	-108.8048
		a ₆	33.1631

2.4. Coolant Channel

The coolant channel is the active fuel height (52.25 cm), and the flow wetted perimeter and area based upon the element diameter (3.747 cm), and the hexagonal pitch (4.171 cm) of the element grid.

2.5. Reactivity Feedback

Razorbac utilizes five reactivity feedback mechanisms that compensate for control system reactivity inputs which are determined from MCNP calculations:

- Fuel temperature: representing the Doppler broadening of the fuel absorption cross section.
- Fuel expansion: representing the local fuel density change, as well as the outer fuel surface area change.
- Cladding expansion: representing the change in local moderator-to-fuel ratio as the coolant channel area changes with clad expansion/contraction.
- Coolant density: representing the change in moderation and absorption as the density of the coolant changes.
- Coolant temperature: representing the change in the local neutron energy spectrum as the coolant temperature changes.

The reactivity feedback coefficient for fuel temperature is given by

$$\frac{d\rho}{dT^{fuel}} = A_{ft} + \frac{B_{ft}}{\sqrt{T_{fuel}}}$$

where T_{fuel} is the absolute temperature. The coefficients are $A_{ft} = -0.00139$ $\$/K$ and $B_{ft} = -0.0743$ $\$/K^{0.5}$.

The reactivity feedback coefficient for fuel expansion is given by the summation of two components, where the first component is

$$\frac{d\rho}{dR}^{fuel} = A_{fr} + B_{fr}R_{fuel}$$

where R_{fuel} is the outer radius of the outer fuel pellet. The coefficients are $A_{fr} = -4167.724$ \$/cm and $B_{fr} = 1243.282$ \$/cm².

The second component of the reactivity feedback coefficient for fuel expansion is given by

$$\frac{d\rho}{d\Delta R}^{fuel} = C_{fr}$$

where ΔR_{fuel} is the overall thickness of the fuel pellets (the gap between the inner and outer pellets is essentially ignored). The coefficient is $C_{fr} = 42.786$ \$/cm.

The reactivity feedback coefficient for clad expansion is given by the summation of two components, where the first component is

$$\frac{d\rho}{dR}^{clad} = A_{cr}$$

where R_{clad} is the outer radius of the clad. The coefficient is $A_{cr} = -115.06$ \$/cm.

The second component of the reactivity feedback coefficient for clad expansion is given by

$$\frac{d\rho}{d\Delta R}^{clad} = B_{cr}$$

where ΔR_{clad} is the thickness of the clad. The coefficient is $C_{cr} = -100.85$ \$/cm.

The coolant density feedback is given as -0.43 \$/%void.² The coolant temperature feedback is given as -0.0014 \$/K.

As noted above, these values have been computed using MCNP. However, the MCNP runs and resulting reactivity coefficients have not been formally documented as calculation at this stage of Razorback development. The determination of these reactivity coefficients should be formally documented for the use in Razorback for DSA analyses.

² The unit “%void” is calculated as $(\rho_o - \rho)/\rho_o * 100$, where ρ_o is the initial reference density of the coolant, and ρ is the “current” density of the coolant.

[This page intentionally left blank.]

3. COMPARISON TO ANALYTICAL SOLUTIONS

3.1. Reactor Kinetics

The reactor kinetics model of the code has been evaluated previously in Ref 7. In this previous evaluation, the code was used to simulate benchmark cases for step, ramp, and sinusoidal reactivity additions which were documented in Ref. 8. The code results were in excellent agreement with the benchmark results. Tables 5 through 10 below present selected results from Ref. 7.

Table 5. Point Kinetic Benchmark Evaluation for -\$1.0 Step Addition.

Time (s)	Code Result	Benchmark	% Difference
0.1	5.2049990E-01	5.205642866E-01	-0.012369
1.0	4.3332231E-01	4.333334453E-01	-0.002570
10.0	2.3610794E-01	2.361106508E-01	-0.001148
100.0	2.8667533E-02	2.866764245E-02	-0.000382

Table 6. Point Kinetic Benchmark Evaluation for -\$0.5 Step Addition.

Time (s)	Code Result	Benchmark	% Difference
0.1	6.9885920E-01	6.989252256E-01	-0.009447
1.0	6.0704475E-01	6.070535656E-01	-0.001452
10.0	3.9607494E-01	3.960776907E-01	-0.000694
100.0	7.1582682E-02	7.158285444E-02	-0.000241

Table 7. Point Kinetic Benchmark Evaluation for \$0.5 Step Addition.

Time (s)	Code Result	Benchmark	% Difference
0.1	1.5332115E+00	1.533112646E+00	0.006448
1.0	2.5115239E+00	2.511494291E+00	0.001179
10.0	1.4215038E+01	1.421502524E+01	0.000090
100.0	8.0060942E+07	8.006143562E+07	-0.000617

Table 8. Point Kinetic Benchmark Evaluation for \$1.0 Step Addition.

Time (s)	Code Result	Benchmark	% Difference
0.1	2.5158849E+00	2.515766141E+00	0.004721
0.5	1.0362726E+01	1.036253381E+01	0.001855
1.0	3.2183405E+01	3.218354095E+01	-0.000422
10.0	3.2469217E+09	3.246978898E+09	-0.001762
100.0	---*	2.596484646E+89	---*

*Run terminated shortly after 10.0 seconds due to prohibitively slow run time.

Table 9. Point Kinetic Benchmark Evaluation for \$0.1/s Ramp Addition.

Time (s)	Code Result	Benchmark	% Difference
2.00	1.3382200E+00	1.338200050E+00	0.001491
4.00	2.2284412E+00	2.228441897E+00	-0.000031
6.00	5.5818737E+00	5.582052449E+00	-0.003202
8.00	4.2780238E+01	4.278629573E+01	-0.014158
10.00	4.5061295E+05	4.511636239E+05	-0.122056
11.00	1.7852862E+16	1.792213607E+16	-0.386528

Table 10. Point Kinetic Benchmark Evaluation for \$2.0 Step Addition with Feedback.

Time (s)	Code Result	Benchmark	% Difference
10.0	1.0338084E+02	1.033808535E+02	-0.000013
20.0	3.9138865E+01	3.913886903E+01	-0.000010
30.0	2.2003775E+01	2.200377721E+01	-0.000010
40.0	1.4493671E+01	1.449367193E+01	-0.000006
50.0	1.0318610E+01	1.031861108E+01	-0.000010
60.0	7.6633185E+00	7.663319203E+00	-0.000009
70.0	5.8293948E+00	5.829395378E+00	-0.000010
80.0	4.4994266E+00	4.499427073E+00	-0.000011
90.0	3.5074223E+00	3.507422663E+00	-0.000010
100.0	2.7551266E+00	2.755126886E+00	-0.000010

3.2. Fuel Element Heat Transfer

A comparison of the peak measured reactor power from the ACRR's Diagnostic System and those predicted by Razorback are shown in Table 1. The Razorback values are obtained from simulations using the nominal worth as input. Figure 5 displays the results in Table 1 graphically.




Figure 1. Schematic of Fuel Element for Analytical Verification.

To facilitate an analytical solution, the thermal conductivities of the materials were set at constant (non-temperature dependent) values of 0.16 W/cm-K, 0.5 W/cm-K, and 0.2 W/cm-K for the BeO-UO₂, niobium, and stainless steel, respectively. The inner radius boundary condition is a zero temperature gradient (zero net heat flux/symmetry), and the outer radius boundary condition was a constant 120°C surface temperature.




Figure 2. Razorback Fuel Element Temperature vs. an Analytical Result.




Figure 3. Relative Error of Fuel Temperature Prediction and Analytical Solution.

[This page intentionally left blank.]

4. COMPARISON TO ACRR PULSE OPERATIONS

Razorback was run to simulate the pulse operations 9716, 9718, 9719, and 9720 which were annual calibration pulses performed in January 2011. These were, respectively, nominal \$1.50, \$2.00, \$2.50, and \$3.00 pulse operations. The data from these 2011 operations were selected because the necessary data files (i.e., the pulse diagnostic report and the console log report) were available on the ACRR “Z” drive. Excerpts from the pulse diagnostic reports and the console log reports are included in Appendix B.

It must be noted that the Diagnostic System used to measure and evaluate pulse operations is not a formally calibrated system. The sensitivities (e.g., nA/MW) of the self-powered neutron detectors (SPND) have been calibrated to ACRR power operation in the past (Ref. 9), but that practice no longer continues. Instead, the sensitivities are adjusted regularly so that reactor yield via the SPNDs matches the yield determined by exposure of dosimetry in the ACRR’s central cavity. There is a report which documents reasonable agreement of the reactor yield determined by the Diagnostic System with dosimetry measurements (Ref. 12). While the Diagnostic System data is the only available data for comparison of pulse and TRW operations, and is believed to reasonably characterize the performance of the ACRR, work is clearly needed to provide a documented calibration basis for the results.

The Razorback values are obtained from simulations using the nominal worth as input. Specifically, a Transient Rod bank initial position was selected to achieve the desired pulse reactivity worth, and Razorback was run. If the desired total reactivity worth was not achieved, then the initial Transient Rod bank position was changed, and Razorback was run again. Once the desired reactivity worth was achieved, then the Razorback simulation was “officially” run.

Actual ACRR pulse operations do not pneumatically eject the transient rods at $t=0$. Rather, the ejection of the transient rods is set to occur at a prescribed time delay (typically on the order of 130-170 ms after time zero). After this prescribed delay time, another time delay occurs associated with the time required for the opening of the valves which provide the pressurized nitrogen gas which drives the transient rods upward.

The ACRR pulse were performed in Pulse Reduced Tail mode (i.e., after a preset Rod Hold Up (RHU) time, the control, safety, and transient rod banks are dropped from their current positions). As such, the Pulse Reduced Tail mode was selected in the Razorback simulations. The RHU time functions essentially as a scram signal for the ACRR to initiate dropping of the control, safety, and transient rods to shut down the reactor. In its simulation, Razorback accounts for a scram delay time (a time delay in the electrical circuitry of the scram system between the initial scram signal, and the initiation of dropping rods). A value of 50 ms is used in the pulse simulations. Razorback also accounts for the time required for the rods to fall from a full up position. The simulations here utilize a value of 0.5 seconds, which was selected to reasonably fit the power tail decay.

Figures 4 through 11 show the results of the Razorback simulations superimposed on the ACRR Diagnostic System power measurement channel results. The timing of the transient rod ejection in the simulations (i.e., the initial pulse start time and nitrogen valve delay time) were set in the

Razorback input so that the resulting times of the pulse peaks would match the ACRR data. This allows for a time-matched comparison of the power traces when plotted on the same time scale. More importantly, it also ensures that the RHU time in the simulation functions as it would at the ACRR.




Figure 4. Razorback Simulation of a \$1.50 Pulse Operation (#9720).




Figure 5. Razorback Simulation of a \$1.50 Pulse Operation (#9720) Showing the Pulse Tail.




Figure 6. Razorback Simulation of a \$2.00 Pulse Operation (#9719).




Figure 7. Razorback Simulation of a \$2.00 Pulse Operation (#9719) Showing the Pulse Tail.




Figure 8. Razorback Simulation of a \$2.50 Pulse Operation (#9718).




Figure 9. Razorback Simulation of a \$2.50 Pulse Operation (#9718) Showing the Pulse Tail.




Figure 10. Razorback Simulation of a \$3.00 Pulse Operation (#9716).




Figure 11. Razorback Simulation of a \$3.00 Pulse Operation (#9716) Showing the Pulse Tail.

4.1. Predicted Reactor Peak Power

A comparison of the peak measured reactor power from the ACRR's Diagnostic System and those predicted by Razorback are shown in Table 11. Figure 12 displays the results in Table 1 graphically. Good agreement is seen for the \$2.00 and higher pulses. The reason for the larger discrepancy for the \$1.50 pulse is not currently known.

Table 11. Reactor Peak Power Comparison for Pulse Operations.

RUN #	9720	9719	9718	9716
Pulse Size (\$) (nominal)	1.50	2.00	2.50	3.00
ACRR Diagnostic System Peak Power (GW) ^a	1.4	7.1	16.4	30.8 ^b
Razorback Peak Power (GW)	1.62	6.95	16.60	30.19
Deviation (%)	13.3%	-2.1%	1.2%	-2.0%

a. The Diagnostic System records power level from three channels. The peak power reported here is the average of the peaks for Channels 1, 2 and 3.

b. The Channel 1 signal was clipped in this operation, so the value here is the average of the peaks for Channels 2 and 3.




Figure 12. Comparison of Predicted and ACRR Peak Power for Several Pulses.

4.2. Predicted Reactor Yield

The reactor yield parameters used to characterize a pulse at the ACRR are as follows:

- Yield at Peak: This parameter is determined by integrating the pulse power history up to the time of the pulse peak.
- Yield at Peak + 3FWHM: This parameter is determined by integrating the pulse power history up to a time equal to the time of the pulse peak plus three times the FWHM (full width at half-maximum (see Section 4.4)). This time span is intended to result in value which characterizes the energy release of the pulse prior to significant delayed neutron effects.
- Total Yield: This parameter is determined by integrating the pulse power history all the way to the end time of the Diagnostic System data recording. This is typically approximately 12 seconds from time zero for the pulse operation. This time span is intended to result in value which characterizes the total energy release of the pulse including the pulse “tail” which is due to delayed neutron effects.

Figure 13 illustrates the integration timespans for each of these yield parameters.




Figure 13. Depiction of the Integration Ranges of the Reactor Yield Parameters.

A comparison of the reactor yield (i.e., the pulse energy release determined by integrating the pulse power history) from the ACRR's Diagnostic System and that predicted by Razorback for the 2011 calibration pulses is shown in Table 12. The Razorback values are obtained from simulations using the nominal worth as input. The results are in reasonable agreement with the ACRR data. It is unclear at this time why the yield at the pulse peak for the \$1.50 pulse deviates more than for the other pulse simulations. The deviation for the 3xFWHM yield for the \$1.50 pulse may be related to the values used for rod drop delay time, as the peak of the pulse occurs about 40 ms after the RHU time is reached. The discrepancy for the total yield for the \$3.00 pulse may be related to the determination of the ACRR tail energy contribution, since Fig. 11 shows that Channel 2 differs significantly from Channels 1 and 3 in the pulse tail timeframe. Figures 14-16 display the results in Table 12 graphically.

Table 12. Reactor Yield Comparison for Pulse Operations.

RUN #	9720	9719	9718	9716
Pulse Size (\$) (nominal)	1.50	2.00	2.50	3.00
ACRR Diagnostic System				
Yield @ Peak (MJ)	20.9	51.2	81.8	118.5
Yield @ 3xFWHM (MJ)	46.3	107.3	171.7	242.9
Yield @ Total (MJ)	54.9	125.3	201.7	294.1
Razorback				
Yield @ Peak (MJ)	23.7	52.1	83.6	117
Yield @ 3xFWHM (MJ)	50.8	109.3	174.1	240.9
Yield @ Total (MJ)	56.8	125	196	267.4
Deviation				
Deviation @ Peak (%)	13.4%	1.8%	2.2%	-1.3%
Deviation @ 3xFWHM (%)	9.7%	1.9%	1.4%	-0.8%
Deviation @ Total (%)	3.5%	-0.2%	-2.8%	-9.1%




Figure 14. Comparison of Predicted and ACRR Reactor Yield at Pulse Peak for Several Pulses.




Figure 15. Comparison of Predicted and ACRR Reactor Yield at Peak+3FWHM for Several Pulses.




Figure 16. Comparison of Predicted and ACRR Total Reactor Yield for Several Pulses.

4.3. Predicted Fuel Temperatures

A comparison of the peak measured fuel temperatures from the ACRR's Plant Protection System (PPS) and those predicted by Razorback for four pulse operations are shown in Table 13. The temperature input to the PPS is from one of two instrumented fuel elements, each having three thermocouple positioned to measure fuel temperature at the mid-plane of the fuel. The ACRR data below was from the PPS-1 instrumented element in core location 218.

The Razorback temperature values are obtained from simulations using the nominal reactivity worth as input. The "measured" fuel temperature in the Razorback code was set so that the data output was equal to the innermost fuel material node at the mid-plane of the simulated element. The results show Razorback predicting the peak fuel temperatures within 2 to 4% of the PPS instrumented element. Figure 17 displays the results in Table 13 graphically.

Table 13. PPS Peak Fuel Temperature Comparison for Pulse Operations.

RUN #	9720	9719	9718	9716
Pulse Size (\$) (nominal)	1.50	2.00	2.50	3.00
ACRR Plant Protection System (PPS)				
Peak Fuel Temperature (°C) – PPS1/TC2*	239	454	656	860
Razorback				
Peak Fuel Temperature (°C)	248.6	466.7	672.4	865.6
Deviation (%)	4.0%	2.8%	2.5%	0.7%

*TC2 refers to thermocouple channel #2 for the PPS drawer shown




Figure 17. Comparison of Predicted and ACRR Fuel Temperatures for Several Pulses.

4.4. Predicted Reactor Pulse Width Parameters

The pulse width parameters used to characterize a pulse are as follows:

- **FWHM:** Full Width at Half-Maximum. This parameter is determined by finding the time, before and after the pulse peak, when the power level is equal to one-half of the peak power.
- **LEHM:** Leading Edge (Width) at Half-Maximum. This parameter is the time difference between the one-half of peak power point before the pulse peak and the pulse peak. For a symmetrical pulse, this timespan would be one-half of the FWHM.
- **TEHM:** Trailing Edge (Width) at Half-Maximum. This parameter is the time difference between the one-half of peak power point after the pulse peak and the pulse peak. For a symmetrical pulse, this timespan would be one-half of the FWHM.
- **LE/TE Ratio:** Leading Edge/Trailing Edge Ratio. This parameter is simply the ratio of the LEHM to the TEHM. For a symmetrical pulse, this ratio would be 1. As such, this provides an indication of the asymmetry of the actual pulse. The impact of delayed neutrons on the pulse shape would lead to an $LE/TE < 1$.

Figure 18 illustrates these pulse width parameters.




Figure 18. Depiction of Pulse Width Parameters.

A comparison of the measured pulse width parameters from the ACRR's Diagnostic System and those predicted by Razorback are shown in Table 14. The Razorback values are obtained from simulations using the nominal worth as input. The deviations are nominally in the +/-5% range. Figure 19 displays the full-width at half-maximum (FWHM) results in Table 14 graphically.

Table 14. Pulse Shape Comparisons for Pulse Operations.

RUN #	9720	9719	9718	9716
Pulse Size (\$ (nominal)	1.50	2.00	2.50	3.00
ACRR FWHM (ms)	27.12	13.24	9.20	7.24
Razorback FWHM (ms)	26.79	13.75	9.25	7.07
Deviation (%)	-1.2%	3.9%	0.5%	-2.3%
ACRR LEHM (ms)	12.88	6.44	4.48	3.60
Razorback LEHM (ms)	12.99	6.69	4.50	3.46
Deviation (%)	0.9%	3.9%	0.4%	-3.9%
ACRR TEHM (ms)	14.24	6.88	4.72	3.64
Razorback TEHM (ms)	13.80	7.06	4.74	3.61
Deviation (%)	-3.1%	2.6%	0.4%	-0.8%
ACRR Ratio LE/TE	0.904	0.936	0.949	0.989
Razorback Ratio LE/TE	0.941	0.948	0.949	0.958
Deviation (%)	4.1%	1.2%	0.0%	-3.1%




Figure 19. Comparison of Predicted and ACRR Pulse Widths for Several Pulses.

4.5. Predicted Reactor Minimum Period

A comparison of the minimum reactor period determined from the ACRR's Diagnostic System and those predicted by Razorback are shown in Table 15. The minimum period value selected from the Diagnostic System data report was the "average" minimum period, as opposed to selecting the minimum period from Channels 1, 2, or 3. The "averaging" algorithm within the Diagnostic System coding should be reviewed for the final V&V effort.

Table 15. Minimum Period Comparison for Pulse Operations.

RUN #	9720	9719	9718	9716
Pulse Size (\$) (nominal)	1.50	2.00	2.50	3.00
Minimum Period				
ACRR (ms)	7.76	3.42	2.34	1.74
Razorback (ms)	6.93	3.49	2.37	1.88
Deviation (%)	-10.7	2.0	1.3	8.0

The interest in this parameter is that the minimum reactor period provides a means, assuming no appreciable delayed neutron effects or reactivity feedback effects, to determine the reactivity addition of the pneumatically-ejected transient rods, given a value for Λ/β .³ As shown in Table 15, except for the \$1.50 case, Razorback predictions for minimum period are quite good (within 3%). However, if one computes a reactivity addition based on the minimum period (see Table 16), the values obtained using the ACRR Diagnostic System minimum period are low with regard to the presumed reactivity addition. If one uses $\Lambda=25.5 \mu\text{s}$ for the ACRR values, the results are much closer to the presumed reactivity.

Table 16. Estimation of Reactivity Addition Using the Minimum Period.

RUN #	9720	9719	9718	9716
Pulse Size (\$) (nominal)	1.50	2.00	2.50	3.00
Minimum Period-Based Reactivity Addition				
ACRR (\$) ^a	1.42	1.96	2.40	2.89
Razorback (\$) ^b	1.50	2.00	2.47	2.86

a. Using $\Lambda=24 \text{ ms}$ and $\beta_{\text{eff}}=0.0073$

b. Using $\Lambda=25.5 \text{ ms}$ and $\beta_{\text{eff}}=0.0073$

³ The Diagnostic System appears to utilize a value of 0.003288 ($\Lambda=24 \mu\text{s}$, $\beta=0.0073$). Recall that Razorback uses a slightly different generation time ($\Lambda=25.5 \mu\text{s}$).

There is another issue, however, with the minimum periods determined by the ACRR Diagnostic System. Figure 20 shows the reactor period derived as $\tau = \Delta t / \ln(P_n / P_{n-1})$ from the data recorded in the ACRR Diagnostic System data report (the \$1.50 Shot #9720 is used here). As seen in Fig. 20, the signal is quite noisy in the region where one would expect to extract the minimum period. Although the algorithm is not readily available, it is possible that the Diagnostic System software adequately filters the data to obtain a true value for the minimum period. However, it would seem prudent to seek a means to reduce the noise for the power channels, or use another detector to more confidently determine the minimum period.




Figure 20. ACRR Reactor Period Produced From Tabular Power/Time Data in the Diagnostic System Report for Pulse 9720 (\$1.50).

Since there is no “noise” in the Razorback simulation, the reactivity addition as computed using the minimum period should be identical to the input reactivity. This is the case for the \$1.50 and \$2.00 pulse simulation results shown in Table 16. However, the results for the \$2.50 and \$3.00 pulse in Table 16 are less than the input reactivity. This is due to the impact of reactivity feedback attaining appreciable levels prior to the addition of the full reactivity input. At the ACRR, this phenomenon is often referred to colloquially as “walking on the rods,” but is referred to in the ACRR Technical Safety Requirements as “dynamic reactivity worth” (Ref. 10). The time required to fully eject the Transient Rod bank, using the normal pneumatic system settings, is insufficient to attain full reactivity worth addition prior to fuel temperature reactivity feedback. Thus, in terms of resulting pulse parameters, the effective reactivity worth of the

Transient Rod bank is less than what would be attained if the addition were near instantaneous (or at least occurred faster than appreciable feedback is developed). This appears to be happening in the Razorback results for \$2.50 and greater pulse reactivity additions. Thus, Razorback may be able to predict the “dynamic reactivity worth” of the Transient Rod bank, but the timing of the Transient Rod bank ejection should be measured/verified at the ACRR to ensure that the Razorback model adequately predicts the ejection timing.

5. COMPARISON TO ACRR TRANSIENT ROD WITHDRAWAL OPERATIONS

Simulations using Razorback were performed for ACRR Runs 9022 and 9023. These were both TRW operations, with relatively similar TRW programs beginning from a position of 3500 units. The Console Logs are included as Appendix B. An initial power level of 1.2 kW (0.05% of full power) was utilized for both simulations, and the pool water was assumed to be at 20°C. The results are shown in Figs. 22 and 23, which show ACRR power levels as measured by Channels 1, 2, and 3 of the Diagnostic System, along with the power level as determined by the Razorback simulation.

Razorback achieves a good match with the initial pulse resulting of TRW operation 9022, but both the peak power and timing of the pulse peak are off for TRW operation 9023. A possible reason for the discrepancy is that the demanded (or programmed) TR bank position vs. time, which is an input to the TRW controller, is not necessarily achieved. The actual TR bank position vs. time is not available, but may have been such that the reactivity addition resulting in the initial pulse was not as high as that demanded by the controller.

In general, the Razorback results demonstrate reasonable agreement with the TRW operations. This is considered to be noteworthy given the interplay of the various reactivity feedback mechanisms (i.e., fuel temperature, fuel and cladding expansion, coolant density and temperature). Note that the second peak power level in both TRWs is not attained in the Razorback simulations. This may be indicative of the simulated reactivity feedback being stronger than it should be (due to over-estimated coolant channel conditions, or over-estimated reactivity coefficients), or perhaps due to inadequate representation of the transient rod reactivity worth for the position range at the time near the second peak ($5.5 \text{ sec} < t < 6.5 \text{ sec}$).




Figure 21. Razorback Simulation of TRW Operation 9022.




Figure 22. Razorback Simulation of TRW Operation 9023.

[This page intentionally left blank.]

6. COMPARISON TO A SLOW REACTOR TRANSIENT OPERATION

On February 2, 2015, a planned slow reactor transient was conducted with the intent of stepping down in reactor power in controlled increments, attaining a steady power level for a few minutes after each step down. Specifically, the following operation plan was followed:

- Achieve steady-state at ~90% of full power.
- Drive the control rod bank in 50 units, and allow the reactor to attain a new steady power level.
- Drive the control rod bank in 100 units, and allow the reactor to attain a new steady power level.
- Drive the control rod bank in 150 units, and allow the reactor to attain a new steady power level.
- Drive the control rod bank in 200 units, and allow the reactor to attain a new steady power level.
- Drive the control rod bank in 200 units, and allow the reactor to attain a new steady power level.
- Drive the control rod bank to full down, and allow the reactor to attain a new steady power level.

This operation was simulated in Razorback by constructing a set of control rod operation commands to match the actual control rod motion of the ACRR as recorded by the Logmaster computer. The control rod commands input to Razorback were as follows:

*----- -----		
* Control Rod Bank Control	Number of CR Bank Commands	
* (1=on w/curve, 0=off, 2=ramp)	(up to 20)	
*----- -----		
1		12
*----- -----		
* CR Start	CR End	CR Speed (cm/s)
* Time (s)	Time (s)	or Ramp (\$/s)
*----- -----		
0.0	5.3	-0.10
5.3	204.0	0.00
204.0	213.9	-0.10
213.9	453.0	0.00
453.0	467.9	-0.10
467.9	738.0	0.00
738.0	758.2	-0.10
758.2	1108.0	0.00
1108.0	1128.2	-0.10
1128.2	1558.0	0.00
1558.0	1754.4	-0.10
1754.4	3600.0	0.00
*-----		

The comparison of the Razorback rod motion due to this input with the ACRR control rod motion is shown in Figure 23.




Figure 23. Comparison of ACRR and Razorback Control Rod Bank Motion During Operation 11278.

Figures 24 and 25 show the results for the power and “measured” fuel temperature history of the Razorback simulation compared to the ACRR power (Wide Range Log Power, Channel 1) and temperature (PPS1-TC2) history. The power history results match reasonably well, with better agreement at power levels above about 20-30 %Full Power (%FP). A significant discrepancy arises around 10-20%FP. The temperature history matches well in general shape, but there is clearly an offset in the magnitude of the predicted temperature which is on the order of 150-200°C. This offset is similar in magnitude to that seen in the comparison of steady-state fuel temperatures (see Section 7), and is expected to be due to the same factors discussed in Section 7.

Regarding the significant discrepancy for the power history shortly after the 1200 second mark, Figure 26 presents the reactivity feedback components computed in the Razorback simulation. The fuel temperature reactivity feedback is clearly the dominant factor, contributing bulk of the positive feedback as the fuel temperature decreases in the power stepdown. However, as the fuel cools down, the fuel, niobium, and cladding expanded dimensions begin to contract back to their original room temperature dimensional state. The feedback from the cladding contraction is seen to become relatively significant from 1100 s to 1300 s. The power history discrepancy may be due to either the cladding contraction or the cladding feedback coefficients being over estimated.




Figure 24. Comparison of Razorback Predicted Power History to Operation 11278.



Figure 25. Comparison of Razorback Predicted Fuel Temperature for Operation 11278.




Figure 26. Components of Reactivity Feedback in Razorback Simulation of Operation 11278.

[This page intentionally left blank.]

7. COMPARISON TO ACRR STEADY STATE OPERATION

The Razorback code was run in steady-state mode to compute estimates of the measured fuel temperature in the ACRR for various power levels. The results are shown in Fig. 27. The data presented in Fig. 27 for the actual ACRR measured fuel temperatures was based on a power-law correlation of fuel temperatures measured in December 1999 testing, when the ACRR was returned to pulse operation mode.⁴ Also included on Fig. 27 are temperatures corresponding to the power plateaus for Operation 11278 (see Section 6). Thus, the ACRR temperature correlation appears to overestimate fuel temperature. Razorback clearly predicts higher fuel temperatures for all appreciable power levels.




Figure 27. Comparison of Steady-State Fuel Temperatures.

Figures 28 and 29 show the error in the predicted temperatures (absolute and relative, respectively) as a function of reactor power level. Potential causes for the errors, which should be investigated in future work include:

- The actual fuel pellet dimensions may be such that the gaps between the fuel pellets and the niobium fuel cup are smaller than indicated on drawings, which would lead to lower predicted fuel temperatures.
- The assumption of plane strain for the fuel element material thermal expansion is underestimating the magnitude of the thermal expansion.

⁴ The correlation was presented at an ACRR Committee meeting on December 6, 1999 (Ref. 11).




Figure 28. Difference in Predicted vs. ACRR Fuel Temperature.




Figure 29. Relative Difference in Predicted vs. ACRR Fuel Temperature.

8. CONCLUSIONS

The results of this initial V&V effort are quite promising. In Section 3, it is seen that the agreement of the code results with analytical solution data is excellent for both the reactor kinetics model (covering a wide variety of reactivity inputs) and the heat transfer within a fuel element. An analytical solution for the coolant channel model is not presented due to the complicated nature of the coupled nonlinear partial differential equations governing its behavior. In addition, an analytical check on the thermal expansion of the fuel element materials is not presented. Such an analytical solution should be pursued to verify the thermal expansion model implementation.

The pulse operation simulations agree very well with the Diagnostic System data. While further work is needed to document the determination of reactivity feedback coefficients, the values utilized appear to be adequate. Based on the results herein, the beta release is capable of simulating normal ACRR pulse operations.

The TRW operation simulations agree reasonably well with the Diagnostic System data. The discrepancies in initial pulse peak power and timing may be attributable to actual vs. demanded Transient Rod bank position for the TRW operation. TRW mode is not currently available, but new TRW operations should be run when it becomes available in order to obtain additional and more complete data for V&V comparison. Based on the results herein, the beta release is capable of simulating normal ACRR TRW operations. However, further work is needed to determine if better Transient Rod bank worth curves or feedback coefficients improve the accuracy of the simulations in the later time portion of the TRW operations.

The general transient operation simulation agrees well with the ACRR reactor power history data. However, there is a clear offset in the prediction of the ACRR measured fuel temperatures for that power history. The offset also arises in the prediction of ACRR fuel temperature with Razorback in steady-state mode. Further work is needed to determine the reason for this offset in predicted fuel temperatures. Likewise, fuel coolant channel outlet temperature measurements are needed to address the validation of the coolant channel flow model. Based on the results herein, the beta release is capable of simulating normal ACRR transient and steady-state operations, but predicted fuel temperatures are conservatively overestimated.

The beta release of the Razorback code is considered adequately verified and validated, but further work is needed prior to the full release of the code.

[This page intentionally left blank.]

9. RECOMMENDATIONS FOR FURTHER WORK

The following areas for additional work have been identified over the course of developing and evaluating the results presented herein:

- An analytical solution for verification of the thermal expansion model is needed.
- The final V&V report should address the selection of the most suitable delayed neutron precursor group data.
- The values used for reactivity feedback coefficients should be documented in formal calculations of record.
- A means of providing a documented calibration basis for the Diagnostic System is needed.
- A means of reducing the Diagnostic System power trace noise in order to better estimate the minimum reactor period should be pursued.
- The source of the discrepancy between the predicted fuel temperatures and the ACRR fuel temperatures, while conservative in regards to safety analysis, should be determined.
- Obtain channel outlet temperature measurements for use in V&V of steady-state and transient simulations.

[This page intentionally left blank.]

10. REFERENCES

1. Duderstadt, J. J. and L. J. Hamilton, Nuclear Reactor Analysis, John Wiley & Sons, Inc., 1976.
2. Coats, R. L., et. al., "Prompt-Period Measurement of the Annular Core Research Reactor Prompt Neutron Generation Time," SAND91-0501, Sandia National Laboratories, July 1994.
3. Pickard, P. S., and J. P. Odom, "Reactor Physics Design Calculations for the ACPR Upgrade," SAND80-0764, Sandia National Laboratories, February 1982.
4. Keepin, R. G., Physics of Nuclear Kinetics, Addison-Wesley Publishing Company, Inc., Reading Massachusetts, 1965.
5. Pickard, P. S., and J. P. Odom, "Sandia Reactor Kinetics Codes: SAK and PK1D," SAND77-1211, Sandia National Laboratories, January 1978.
6. Internal SNL Technical Area V Calculation Document, CALC-ACRR-2014-003, "ACRR Peaking Factor Distributions," December 19, 2014.
7. Internal SNL Technical Area V Evaluation Document, EE-TAV-2013-001, "Evaluation of RAZORBACK's Point Kinetic Model Against Numerical Benchmarks," July 25, 2103
8. Ganapol, B. D., "A highly accurate algorithm for the solution of the point kinetics equations," *Annals of Nuclear Energy*, 62 (2013), pp. 564-571.
9. Internal SNL Memorandum, K. R. Boldt to F. M. McCrory, "ACRR SPND Detector Currents for NV/NVT Systems," dated December 22, 1999.
10. Martin, L. E., and L. L. Lippert, "Technical Safety Requirements (TSRs) for the Annular Core Research Reactor Facility (ACRRF)," SAND2008-5637, CN7, Sandia National Laboratories, April 22, 2014.
11. Internal SNL Memorandum, J. S. Philbin to J. W. Bryson, "ACRR Committee Meeting Minutes for December 6, 1999," dated December 7, 1999 (TA-V Record ID#10537).
12. Maestas, B. A., "Annular Core Research Reactor Pulse Diagnostics' Performance Assessment – A Comparison of Nickel & Sulfur Activation to Diagnostics Energy Yield," unpublished internal report, dated Spring 2008.

[This page intentionally left blank.]

APPENDIX A: SAMPLE RAZORBACK INPUT FILE

```

*****
*                                     RAZORBACK Input File
*   Note: an "*" in the first column denotes a comment statement
*****
*                                     CALCULATION AND PRINTING CONTROLS
*****
*-----|-----|-----|
*      Calculation Type      | Total Transient      | Number of      |
*      (1=steady-state,0=transient) | Calculation Time (s) | Title Cards    |
*-----|-----|-----|
*              0              |             12.0      |              7  |
*-----|-----|-----|
*                                     Title Cards
*-----|-----|-----|
*   Simulation of Pulse 9716: Nominal $3.00 Calibration Pulse Jan. 2011
*   - Initial power 0.05% (1.2 kW)
*   - 0.4 second Rod Hold Up time
*   - TR set to position yielding ~$3.00
*   - CR at 24.00 cm; SR at 55.00 cm
*   - N2 valve delay set to approximate time-to-peak
*   - 0.05 second scram delay time; 0.5 second rod fall time
*
*-----|-----|-----|
*   Number of Time Step Ranges | Initial Condition Stabilization |
*   (up to 20)                  | Duration (s) | Time Step (s) |
*-----|-----|-----|
*              1              |             0.0      |             0.01
*-----|-----|-----|
*                                     Time Step Control (TSC)
*                                     (If TSC is off, then
*                                     dt = max time step of range)
*   Time Range      | Time Step      | T/H      | TSC      | TSC      |
*   Begin(s)/End(s) | max(s) / min(s) | dt(s)    | "Error"  | (1=y/0=n) |
*-----|-----|-----|-----|-----|
*   0.0 10000.00    | 1.0d-3 1.0d-9   | 1.0d-3    | 1.0d-3    | 1
*
*
*-----|-----|-----|
*   Number of Print Increment Ranges |
*   (up to 20)                        |
*-----|-----|-----|
*              2
*-----|-----|-----|
*   Print Time Range | screen | plot | file |
*   Begin(s)/End(s) | print  | print | print |
*   incr.(s)         | incr.(s) | incr.(s) | incr.(s) |
*-----|-----|-----|
*   0.0 1.0         | 1.0e-3 | 1.0e-3 | 5.0e-2 |
*   1.0 10000.0     | 1.0e-2 | 1.0e-3 | 5.0e-1 |
*-----|-----|-----|
*   pulse parameter file print | fuel rod screen/file print |
*   (1=yes, 0=no)              | (1=yes, 0=no)              |
*-----|-----|-----|
*              1              |              1
*
*****
*                                     REACTOR POWER AND INITIAL CONDITIONS
*****
*-----|-----|-----|

```

Initial Reactor Power (%)	100% Reactor Power (W)	Element Peak-to-Average
5.0e-02	2.39e+06	1.45

 REACTIVITY ADDITION SYSTEM CONTROLS

Control Rod Bank Control (1=on w/curve, 0=off, 2=ramp)	Number of CR Bank Commands (up to 20)
0	2

CR Start Time (s)	CR End Time (s)	CR Speed (cm/s) or Ramp (\$/s)
0.0	1.0	0.00
1.0	10000.0	0.00

Note: 0.1 cm/s CR Speed = slow speed; 2.0 cm/s CR Speed = fast speed

CR Start Position (cm)	CR down Position (cm)	CR Up Position (cm)
24.00	0.0	55.00

CR Bank Total Worth (\$)	CR Bank Differential Reactivity Curve $\rho/\Delta z = A \sin^2[B(z) + C]$		
	A	B	C
12.00	0.02822125	0.0432	0.31852

Safety Rod Bank Control (1=on w/curve, 0=off, 2=ramp)	Number of SR Bank Commands (up to 20)
0	2

SR Start Time (s)	SR End Time (s)	SR Speed (cm/s) or Ramp (\$/s)
0.0	1.0	0.0
1.0	10000.0	0.0

Note: 0.24 cm/s CR Speed = slow speed, 7.26 cm/s = fast speed

SR Start Position (cm)	SR down Position (cm)	SR Up Position (cm)
55.00	0.0	55.00

```

*
*-----|-----|-----|-----|
*   SR Bank      | SR Bank Differential Reactivity Curve |
*   Total        | drho/dz = A sin2[ B(z) + C]         |
*   Worth ($)    | A           | B           | C           |
*-----|-----|-----|-----|
*         2.15      | 0.02822125 | 0.0432      | 0.31852     |
*
*-----|-----|-----|-----|
*   Transient Rod Bank Control | Number of TR Bank Commands |
*   (0=off, 1=on w/curve)      | (up to 20)                  |
*   (2=pulse, 3=ramp)          |                               |
*-----|-----|-----|-----|
*               2               | 1                             |
*
*-----|-----|-----|-----|
*   TR Start      | TR End      | TR Speed (cm/s) |
*   Time (s)      | Time (s)     | or Ramp ($/s)   |
*-----|-----|-----|-----|
*
*   Pulse Operation (1 TR Bank Command; only TR Start Time is needed)
*   0.165          1.000          0.000
*-----|-----|-----|-----|
*
*-----|-----|-----|-----|
*   TR Start      | TR down      | TR Up           |
*   Position (cm) | Position (cm) | Position (cm)   |
*-----|-----|-----|-----|
*   55.09          43.70          90.00 ($1.50 2011 cal data)
*   50.90          43.70          90.00 ($2.00 2011 cal data)
*   46.85          43.70          90.00 ($2.50 2011 cal data)
*   42.70          42.69          90.00 ($3.00 2011 cal data)
*-----|-----|-----|-----|
*   Note: TR full down = 22.00 cm   TR pedestal down = 43.00 cm
*
*-----|-----|-----|-----|
*   TR Bank      | TR Bank Differential Reactivity Curve |
*   Total        | drho/dz = A sin2[ B(z - z0) + C]     |
*   Worth($)     | A           | B           | C           | z0          |
*-----|-----|-----|-----|-----|
*   4.45          0.0279912   0.0438084   -0.225591   0.0
** 2011 cal data for pulse (z0 not used for pulse)
*
*-----|-----|-----|-----|
*   cubic spline approach for TR reactivity worth data
*   (if number of entries below is non-zero,
*   this will override the TR worth specified above)
*-----|-----|-----|-----|
*
** (0 skips this) (ten entries per line max)
0
*-----|-----|-----|-----|
*   Range of Validity for TR Bank Differential Reactivity Curve
*   lower end (cm) | upper end (cm) |
*-----|-----|-----|-----|
*           12.0           | 85.0            |
*
*-----|-----|-----|-----|
*   Transient Rod Pulse Pneumatic System
*   N2 Valve      | N2           | Piston         | TR           |
*   opening time (s) | Pressure (psig) | Effective Area (cm2) | Mass (kg)   |
*-----|-----|-----|-----|
*   88.0e-3        | 65.0         | 28.96          | 13.75 (for Pulse 9716)
*-----|-----|-----|-----|

```

```

*
* Pulse Rod Holdup (= time after pulse when rods drop back into core)
* Time begins from t=0
* PRT submode all rods drop
* Pulse submode TRs and SRs drop (CRs do not)
*-----|-----|
*      Transient Rod Pulse      |      Pulse Submode      |
*      Rod Holdup Time (s)      |      (Pulse=0 or PRT=1) |
*-----|-----|
*              0.4e0              |              1              |
*
*-----|-----|-----|
* Functional Reactivity Addition | Number of | Time to Turn |
* (0=off, 1=polynomial, 2=sine) | Terms(<=5) | Addition Off (s) |
*-----|-----|-----|
*              0              |              1              |              1e10
*****
*              REACTOR KINETICS PARAMETERS
*****
*-----|-----|-----|
* Neutron Generation | Effective Delayed | No. of Delayed |
* Time (s)           | Neutron Fraction  | Neutron Groups  |
*-----|-----|-----|
*      25.5e-06      |      0.0073      |      6          |
*
*-----|-----|
*              Delayed Neutron
*              Group Decay Constants (1/s) - lambda i's
*              (up to 18 groups allowed -- up to 6 lambdas per line)
*-----|-----|-----|
*      1.27e-02      3.17e-02      1.15e-01      3.10e-01      1.40      3.87
* (Typical ACRR values for 6 groups)
*-----|-----|
*
*-----|-----|
*              Delayed Neutron
*              Group Fractions - beta i's
*              (up to 18 groups allowed -- up to 6 betas per line)
*-----|-----|-----|
*      2.774e-04      1.5549e-03      1.3724e-03      2.9711e-03      9.344e-04      1.898e-04
* (Typical ACRR values 6 groups)
*-----|-----|
*
*-----|-----|-----|
* Fuel Temperature Feedback      | Coolant Reactivity      |
* drho/dT = c1 + c2/(T**0.5)    | Feedback Coefficients   |
* c1      |      c2      | Density      | Spectral      |
* ($/K)   |      ($/K^1/2) | ($/%void)    | ($/K)         |
*-----|-----|-----|
*      -0.00139      -0.0743      -0.43      -0.0014
*
*-----|-----|-----|
* Fuel Expansion Feedback      | Clad Expansion Reactivity |
* Feedback Coefficients       | Feedback Coefficients     |
* c11      |      c12      |      c2      |      c1      |      c2      |
* ($/cm)   |      ($/cm^2) |      ($/cm)   |      ($/cm)   |      ($/cm)   |
*-----|-----|-----|
*      -4167.724      1243.282      42.786      -115.06      -100.85
*
*-----|-----|
*              Reactivity Feedback Scaling and Adjustment Factors

```

```

* ----- Scaling -----|-----|
* Fuel T | Fuel Exp | Clad | Coolant | PLA (not used by code) |
*-----|-----|-----|-----|-----|
*      1.0      1.0      1.0      1.0      1.45
*
*-----|
* Point Kinetics Solver Selection |
* (1=R-K Gill, 2=1st Order Taylor Series) |
*-----|
*
*      1
*
*****
* REACTOR PROTECTION SYSTEM SETTINGS
*****
*
*-----|-----|-----|
* Percent      Reactor      Element
* Power (%)    Power (W)    Power (W)
*-----|-----|-----|
*      115.0e+40      2.50e+46      25.00e+43
*
*-----|-----|-----|
* Reactor      Rod Block      Rod Block
* Period (s)    (1=on,0=off)    Rate (dpm)
*-----|-----|-----|
*      8.50e-20      0      4.0e10
*
*-----|-----|
* Reactor Yield (J)      Fuel Temperature (C)
*-----|-----|
*      1.0e40      1250.0e20
*
*-----|-----|
* Pool Level Scram      Inlet Temperature
* (cm below tank top)    Scram (C)
*-----|-----|
*      100.0e20      40.0e20
*
*-----|-----|
* Scram Delay Time (s)      Rod Fall Time (s)
*-----|-----|
*      0.050      0.5
*
*-----|-----|
* Scram Failure      Manual Scram
* (1 = yes, 0 = no)    Delay Time (s)
*-----|-----|
*      0      10.0
*
*****
* POOL WATER AND POOL WATER COOLING SYSTEM
* INITIAL CONDITIONS AND TRANSIENT(S)
*****
*
*-----|-----|
* Initial Pool Water | Initial Pool Water Level (cm) | Cooling System
* Temperature (C) | (Distance Below Tank Lip) | Heat Removal
*-----|-----|-----|
*      20.0      100.0      0.0
*
*-----|
* Pool Heatup
*-----|

```

```

*   Flag = 0 -> no pool heatup (constant Tpool = Tinlet) |
*   Flag = 1 -> pool heatup by reactor/cooling system (Tpool = Tinlet) |
*   Flag = 2 -> pool temperature ramp (Tpool = Tinlet) |
*   Flag = 3 -> inlet temperature ramp (constant Tpool <> Tinlet) |
* |
*   Flag | Ramp (degC/s) | Start Time (s) | End Time (s) |
*-----|-----|-----|-----|
*       0 |         0.0 |         0.0 |         0.0 |
* |
*-----|-----|-----|-----|
*
*               Loss of Coolant Accident
*   Flag | Start | Break | Effective Reactor |
* (1=on, 0=off) | Time (s) | Size (cm2) | Power (W) |
*-----|-----|-----|-----|
*       0 |    0.1 |   40.64 |       2.0e6 |
* |
*-----|-----|-----|-----|
*
*               Loss of Heat Sink Accident
*   Flag | Start Time | Flowrate Coastdown |
* (1=on, 0=off) | (s) | Time (s) |
*-----|-----|-----|
*       0 |    5.0 |    1.00 |
* |
*-----|-----|
*   Decay Heat Option (1=on,0=off) |
*-----|
*       0
* |
*-----|
*
*****
*               NUMERICAL SOLUTION SETTINGS
*****
*-----|
*   Implicit Formulation Factors |
*-----|
*   Theta | Phi | Psi |
*-----|
*       1.00 |    1.00 |    1.00 |
*-----|-----|-----|
* |
*-----|-----|-----|
*
*               Iteration Error Limits
*   Steady-State | Transient |
*-----|-----|
*   Temperature | Flow | Temperature |
*-----|-----|
*       1.0e-4 |    1.0e-3 |    1.0e-3 |
* |
*****
*               FUEL ELEMENT MODEL
*****
*
*               Standard ACRR Thermal-Hydraulics Model
*-----|-----|-----|-----|
*   Number | Number | Fuel | Fuel Coordinate System Geometry |
* of Fuel | of Fuel | R_inner | 0 = plate geometry |
* Elements | Zones | (cm) | 1 = cylindrical geometry |
* | (10 max) | | |
*-----|-----|-----|-----|
*       236 |    7 | 0.24130 |    1 |
* |
*-----|-----|-----|-----|
*   Zone Outer | Number | Material | Gap? | Fission Energy |
* Radius (cm) | of nodes | Type | (0=n/1=y) | Deposition Fraction |

```

```

*-----|-----|-----|-----|-----|
1.09982      10      1      0      0.97846      BeO-UO2 Fuel
1.11760      10      3      1      0.0          He Gap
1.68402      10      1      0      0.97846      BeO-UO2 Fuel
1.73228      10      3      1      0.0          He Gap
1.77038      10      2      0      0.00400      Nb Cup
1.82245      10      3      1      0.0          He Gap
1.87325      10      4      0      0.00456      SS-304 Cladding
*-----|-----|-----|-----|-----|
*
*-----|-----|-----|
* Material # in which      | Allow      | Allow      |
* fission occurs          | Thermal Expansion | Gap Rad HX |
* (only one per element)  | (0=no,1=yes) | (0=off,1=on) |
*-----|-----|-----|
*              1              1              1
*
*-----|-----|
* # of fuel "Thermocouples" | Radial node(s) of "TC(s)" |
*                          | (at half fuel height)      |
*-----|-----|
*              2              1  5
*
*-----|-----|
* Fuel Pellet Radial Fission Density Peaking Distribution |
* f(r) = A*exp(B*r) + C |
*-----|-----|
* A      | B      | C      |
*-----|-----|
* 0.0157 | 1.9370 | 0.8211 |
*-----|-----|
* Fuel Element Axial Fission Density Peaking Distribution |
* f(z) = SUM{a(i)*(z/H)^(i)} for i = 0 to 6 |
*-----|-----|
* 0.7721 -0.6252 24.0903 -89.6026 141.5383 -108.8048 33.1631 CR @ 27.50 cm
*
*****
* COOLANT CHANNEL MODEL
*****
*
*-----|
* Coolant Channel Option |
* (0 = fuel coupled to coolant, 1 = channel only) |
*-----|
*              0
*
*-----|-----|
* (if Forced Convection) |
* Coolant Type      | Flow Type      | Inlet      | Outlet      |
* (1 = water)      | (1=Natural Conv.) | Pressure    | Pressure     |
*                  | (0=Forced Conv.) | (psia)      | (psia)       |
*-----|-----|
* 1              1              25.0      24.1
*
*-----|-----|
* Coolant n & gamma Heating | Atmospheric Pressure |
* (J/g/J of Rx Power)      | Above Pool Water (psia) |
*-----|-----|
* 0.261e-6              12.5
*
*-----|
* Inlet (Unheated Length) |

```



```

*-----|
*      Total Length (cm)      |      Number of Nodes      |
*-----|-----|
*              0.0              |              0              |
*-----|
*              Inlet Unheated Length Description
*-----|
* Node Height | Flow Area | Wetted Perimeter | Inlet
*   (cm)      |   (cm2)   |         (cm)     | Loss Coefficient
*-----|-----|-----|
*       1.0    |  4.042398 |       11.76998   |          0.0
*-----|
*              Fuel (Heated Length)
*-----|
*      Fuel      |      Number      | Pitch or      | Pitch/Flow Geometry
*      Length (cm) |    of Nodes     | Channel O.D.  | (1=square pitch,2=hex pitch
*-----|-----|-----|
*       52.25    |         52      |       4.171     |          2
*-----|
*              Outlet (Unheated Length)
*-----|
*      Length (cm)      |      Number of Nodes      |
*-----|-----|
*              0.0              |              0              |
*-----|
*              Outlet Unheated Length Description
*-----|
* Node Height | Flow Area | Wetted Perimeter | Inlet
*   (cm)      |   (cm2)   |         (cm)     | Loss Coefficient
*-----|-----|-----|
*       1.0    |  4.042398 |       11.76998   |          0.0
*-----|
*-----|--(not used)--|-----|-----|
*   Chimney      |   Suppress   | Channel Inlet   | Channel Exit
*   Length (cm)  | Boiling (1=y) | Loss Coefficient | Loss Coefficient
*-----|-----|-----|-----|
*       0.0      |         0     |       0.5        |       1.0
*-----|
*
*****
* Test Options (only the "Reactor Only" option is currently available)
*****
*-----|
*              Test Mode
*-----|
*   0 = Normal (no test; next 3 cards not required, so comment out)
*   1 = Specify BCs and/or Conductivities (next 2 cards required)
*-----|
*              0
*-----|
*
* Fuel Element Surface BC  1=convection / 2=constant T --> BC Temp
*              2                      120.0
*
* Fuel Element Material Constant Thermal Conductivity 1=yes / 0=no
*              1
*
* Conductivity (W/cm/K) -- 6 entries required for materials 1-6
*       0.160  0.500  0.160   0.150  0.160  0.160
*
*

```

```

*   Module Selection
*
*-----|
*           Reactor Only Test Option           |
*-----|
*   Reactor Only (1=y/0=no)      |   Energy Yield Feedback ($/J-Rx)   |
*-----|-----|
*                               0                               -3.87597e-4
*
*****
*   Defined Power History Option      (Uses constant Time Step)
*   (1=y/0=no)      (1 Turns Reactor Module Off)
*****
*                               0
*
* if selected, create a power history file (pwrhis.dat)
* to be read in by code
*
*****

```

APPENDIX B: PULSE LOG SHEET EXCERPTS

Operation 9716 Console Log

DATE 01-05-11
TIME 16:56
RUN NO 09716

PPS1

NV 33310
NVT 312
TEMPERATURE 1 PEAK 37
TEMPERATURE 2 PEAK 860
TEMPERATURE 3 PEAK 860

PPS2

NV 34240
NVT 330
TEMPERATURE 1 PEAK 819
TEMPERATURE 2 PEAK 842
TEMPERATURE 3 PEAK 815

FREC

TEMPERATURE 1 PEAK 28
TEMPERATURE 2 PEAK 207

	CR Bank Position (RU)	CR Bank Worth (cents)
TR UP DC	1488	1020.5
Free Field DC	1501	1016.8
Experiment Worth	3.7	

TR Down DC	2410	717.0
TR Bank Worth	303.5	

Setup DC	2400	720.6
Pulse Size	299.9	

	TR Bank Position (RU)	TR Bank Worth (cents)
Setup Pulse Size	4185	309.8

Operation 9716 Diagnostic System Report (Excerpt)

Shot Information		Predicted Values	
Run Number	9716	Expected MW	35500
Operator	Dave Clovis	Expected TTP	0.3125
Date \ Time	1/5/2011 16:52	Expected MJ	286.26
Experimenter Name	ACRR	Expected Fuel Temp	837.2
Experiment Plan #	MP 11	Dialed In MW	32285.51
Package Worth \$	0.037		
Shot Worth \$	3.035		
Rod Hold Up (sec)	0.4		
FREC Mode	Decoupled		
FREC RODS	DOWN		

Comments

	Average	CH-1	CH-2	CH-3	CH-4
Detector		DE2-3	DE4-9	DE5-1	
Detector Calibration		42.6	40.2	40.6	
Channel Type		PXI Amp	SR570 Amp	SR570 Amp	
Average Used		Both	Both	Both	
Period Used		Yes	Yes	Yes	
PEAK DATA:					
Peak (MW)	29605.9	27216.3	31278.5	30395.7	
TTP (sec)	0.34356	0.34208	0.34352	0.34356	
FWHM (sec)	0.00724	0.00768	0.00708	0.00708	
LEHM (sec)	0.0036	0.00252	0.0034	0.0034	
TEHM (sec)	0.00364	0.00516	0.00368	0.00368	
Ratio (LE/TE)	0.989	0.488	0.924	0.924	
Shot Worth	2.851	3.179	3.068	3.029	
YIELD DATA:					
Total Yield (MJ)	294.132	266.532	350.252	270.045	
TTP+3fwhm (MJ)	242.895	236.182	249.605	242.814	
Yield @ Peak (MJ)	118.517	80.292	118.256	115.563	
Min Period (sec)	0.001738	0.001474	0.001554	0.001584	

Operation 9718 Console Log

DATE 01-06-11
TIME 13:39
RUN NO 09718

PPS1

NV 17867
NVT 229
TEMPERATURE 1 PEAK 36
TEMPERATURE 2 PEAK 656
TEMPERATURE 3 PEAK 654

PPS2

NV 18347
NVT 242
TEMPERATURE 1 PEAK 618
TEMPERATURE 2 PEAK 635
TEMPERATURE 3 PEAK 612

FREC

TEMPERATURE 1 PEAK 27
TEMPERATURE 2 PEAK 160

	CR Bank Position (RU)	CR Bank Worth (cents)
TR UP DC	1484	1021.6
Free Field DC	1481	1022.5
Experiment Worth	-0.9	

TR Down DC	2408	717.8
TR Bank Worth	303.8	

Setup DC	2257	771.5
Pulse Size	250.1	

	TR Bank Position (RU)	TR Bank Worth (cents)
Setup Pulse Size	4561	260.5

Operation 9718 Diagnostic System Report (Excerpt)

Shot Information		Predicted Values	
Run Number	9718	Expected MW	18000
Operator	Kraig Deike	Expected TTP	0.3208
Date \ Time	1/6/2011 13:35	Expected MJ	209.34
Experimenter Name	ACRR Staff	Expected Fuel Temp	618.5
Experiment Plan #	OP-2/OP AID 29	Dialed In MW	16398.82
Package Worth \$	-0.009		
Shot Worth \$	2.501		
Rod Hold Up (sec)	0.4		
FREC Mode	Decoupled		
FREC RODS	DOWN		

Comments ACRR Cal pulse per MP-11

	Average	CH-1	CH-2	CH-3	CH-4
Detector		DE2-3	DE4-9	DE5-1	
Detector Calibration		42.6	40.2	40.6	
Channel Type		PXI Amp	SR570 Amp	SR570 Amp	
Average Used		Both	Both	Peak	
Period Used		Yes	Yes	Yes	
PEAK DATA:					
Peak (MW)	16393	16256	16659.8	16292.5	
TTP (sec)	0.34928	0.34904	0.34932	0.34936	
FWHM (sec)	0.0092	0.00916	0.00924	0.0092	
LEHM (sec)	0.00448	0.0044	0.00444	0.00444	
TEHM (sec)	0.00472	0.00476	0.0048	0.00476	
Ratio (LE/TE)	0.949	0.924	0.925	0.933	
Shot Worth	2.378	2.665	2.875	2.839	
YIELD DATA:					
Total Yield (MJ)	201.706	203.771	202.722	189.433	
TTP+3fwhm (MJ)	171.709	170.027	174.429	170.663	
Yield @ Peak (MJ)	81.805	80.265	82.363	80.856	
Min Period (sec)	0.002343	0.001935	0.001716	0.00175	

Operation 9719 Console Log

DATE 01-10-11
TIME 15:56
RUN NO 09719

PPS1

NV 7755
NVT 144
TEMPERATURE 1 PEAK 39
TEMPERATURE 2 PEAK 454
TEMPERATURE 3 PEAK 458

PPS2

NV 7962
NVT 155
TEMPERATURE 1 PEAK 432
TEMPERATURE 2 PEAK 444
TEMPERATURE 3 PEAK 424

FREC

TEMPERATURE 1 PEAK 30
TEMPERATURE 2 PEAK 113

	CR Bank Position (RU)	CR Bank Worth (cents)
TR UP DC	1485	1021.4
Free Field DC	1481	1022.5
Experiment Worth	-1.1	

TR Down DC	2405	718.8
TR Bank Worth	302.6	

Setup DC	2115	821.2
Pulse Size	200.2	

	TR Bank Position (RU)	TR Bank Worth (cents)
Setup Pulse Size	4946	210.9

Operation 9719 Diagnostic System Report (Excerpt)

Shot Information		Predicted Values	
Run Number	9719	Expected MW	7000
Operator	Lance Lippert	Expected TTP	0.3395
Date \ Time	1/10/2011 15:54	Expected MJ	136.15
Experimenter Name	ACRR STAFF	Expected Fuel Temp	413.8
Experiment Plan #	MP-11	Dialed In MW	6528.42
Package Worth \$	-0.011		
Shot Worth \$	2.002		
Rod Hold Up (sec)	0.4		
FREC Mode	Decoupled		
FREC RODS	DOWN		

Comments

	Average	CH-1	CH-2	CH-3	CH-4
Detector		DE2-3	DE4-9	DE5-1	
Detector Calibration		42.6	40.2	40.6	
Channel Type		PXI Amp	SR570 Amp	SR570 Amp	
Average Used		Both	Both	Both	
Period Used		Yes	Yes	Yes	
PEAK DATA:					
Peak (MW)	7092.1	6991.4	7227.2	7061.9	
TTP (sec)	0.36816	0.36788	0.36816	0.3682	
FWHM (sec)	0.01324	0.01324	0.01324	0.0132	
LEHM (sec)	0.00644	0.00636	0.00636	0.00636	
TEHM (sec)	0.0068	0.00688	0.00688	0.00684	
Ratio (LE/TE)	0.947	0.924	0.924	0.93	
Shot Worth	1.947	2.082	2.215	2.398	
YIELD DATA:					
Total Yield (MJ)	125.349	122.929	129.803	125.204	
TTP+3fwhm (MJ)	107.281	105.702	109.316	106.807	
Yield @ Peak (MJ)	51.18	49.785	51.56	50.518	
Min Period (sec)	0.003415	0.002989	0.00266	0.002309	

Operation 9720 Console Log

DATE 01-13-11
TIME 11:04
RUN NO 09720

PPS1

NV 1560
NVT 68
TEMPERATURE 1 PEAK 35
TEMPERATURE 2 PEAK 239
TEMPERATURE 3 PEAK 236

PPS2

NV 1616
NVT 71
TEMPERATURE 1 PEAK 227
TEMPERATURE 2 PEAK 233
TEMPERATURE 3 PEAK 223

FREC

TEMPERATURE 1 PEAK 27
TEMPERATURE 2 PEAK 68

	CR Bank Position (RU)	CR Bank Worth (cents)
TR UP DC	1491	1019.6
Free Field DC	1481	1022.5
Experiment Worth	-2.9	

TR Down DC	2419	713.8
TR Bank Worth	305.8	

Setup DC	1973	869.5
Pulse Size	150.1	

	TR Bank Position (RU)	TR Bank Worth (cents)
Setup Pulse Size	5404	156.5

Operation 9720 Diagnostic System Report (Excerpt)

Shot Information		Predicted Values	
Run Number	9720	Expected MW	1500
Operator	Lonnie Martin	Expected TTP	0.4085
Date \ Time	1/13/2011 11:03	Expected MJ	62.57
Experimenter Name	ACRR staff	Expected Fuel Temp	207.1
Experiment Plan #	MP-11	Dialed In MW	1300.77
Package Worth \$	-0.029		
Shot Worth \$	1.5		
Rod Hold Up (sec)	0.4		
FREC Mode	Decoupled		
FREC RODS	DOWN		

Comments TRW Worth Determination

	Average	CH-1	CH-2	CH-3	CH-4
Detector		DE2-3	DE4-9	DE5-1	
Detector Calibration		42.6	40.2	40.6	
Channel Type		PXI Amp	SR570 Amp	SR570 Amp	
Average Used		Both	Both	Both	
Period Used		Yes	Yes	Yes	
PEAK DATA:					
Peak (MW)	1429.8	1412.8	1457.8	1419.1	
TTP (sec)	0.43896	0.43888	0.43944	0.43904	
FWHM (sec)	0.02712	0.02716	0.02712	0.02708	
LEHM (sec)	0.01288	0.013	0.01328	0.01284	
TEHM (sec)	0.01424	0.01416	0.01384	0.01424	
Ratio (LE/TE)	0.904	0.918	0.96	0.902	
Shot Worth	1.416	1.732	1.702	2.077	
YIELD DATA:					
Total Yield (MJ)	54.787	55.594	57.937	51.656	
TTP+3fwhm (MJ)	46.28	45.804	47.2	45.856	
Yield @ Peak (MJ)	20.892	20.829	21.879	20.667	
Min Period (sec)	0.007756	0.004422	0.004615	0.003002	

Operation 9022 Console Log

DATE 05-30-08
TIME 11:27
RUN NO 09022

PPS1

NV 65
NVT 311
TEMPERATURE 1 PEAK 37
TEMPERATURE 2 PEAK 718
TEMPERATURE 3 PEAK 723

PPS2

NV 98
NVT 306
TEMPERATURE 1 PEAK 732
TEMPERATURE 2 PEAK 769
TEMPERATURE 3 PEAK 752

FREC

TEMPERATURE 1 PEAK 213
TEMPERATURE 2 PEAK 195

	CR Bank Position (RU)	CR Bank Worth (cents)
TR UP DC	1514	1013.1
Free Field DC	1505	1015.6
Experiment Worth	-2.5	

TR Down DC	2818	570.1
TR Bank Worth	443.0	

Setup DC	2668	624.0
Pulse Size	389.1	

	TR Bank Position (RU)	TR Bank Worth (cents)
Setup Pulse Size	3500	388.6

Operation 9023 Console Log

DATE 05-30-08
TIME 12:48
RUN NO 09023

PPS1

NV 44
NVT 308
TEMPERATURE 1 PEAK 35
TEMPERATURE 2 PEAK 722
TEMPERATURE 3 PEAK 726

PPS2

NV 98
NVT 307
TEMPERATURE 1 PEAK 730
TEMPERATURE 2 PEAK 767
TEMPERATURE 3 PEAK 749

FREC

TEMPERATURE 1 PEAK 214
TEMPERATURE 2 PEAK 195

	CR Bank Position (RU)	CR Bank Worth (cents)
TR UP DC	1504	1015.9
Free Field DC	1505	1015.6
Experiment Worth	0.3	

TR Down DC	2818	570.1
TR Bank Worth	443.0	

Setup DC	2654	629.1
Pulse Size	386.8	

	TR Bank Position (RU)	TR Bank Worth (cents)
Setup Pulse Size	3500	388.6

[This page intentionally left blank.]

DISTRIBUTION

1	MS1141	Michael R. Greutman	01383
1	MS1141	Peter V. Subaiya	01383
1	MS1141	Darren G. Talley	01383
1	MS1146	Edward J. Parma, Jr.	01384
1	MS0899	Technical Library	9536 (electronic copy)

